

montagevoorschrift

centrale ontluchtingsset X-tender 125 / X-celler 105



INHOUD VERPAKKING

- 1 x transparante slang
- 1 x eindstopje
- 6 x doorvoerstop voorzien van backfire bescherming

MONTAGE

Knip van de slang 5 stukken van 10 cm af en 1 stukje van 2 cm. Draai de standaardstoppen van de batterij los en vervang deze door de doorvoerstoppen. Sluit de 10 cm slangetjes tussen de doorvoerstoppen zoals de foto boven weergeeft. Schuif het stukje van 2 cm aan één van de uiteinden en druk het stopje hierin. Monteer het restant slang aan het andere uiteinde en leid deze naar buiten.

FITTING INSTRUCTIONS for central exhaust on X-tender 125 / X-celler 105

PACKAGING CONTAINS:

- 1 x transparent tube
- 1 x plug
- 6 x exhaust caps (back-fire protection included).

ASSEMBLY:

Cut 5 pcs. of 10 cm. each from the tube and also 1 pc. of 2 cm. Remove the filling caps on the lid of the battery and replace them by the exhaust caps. Fit the tubes (10 cm) between the exhaust caps as shown on the picture above. Push the tube of 2 cm. on one of the outmost exhaust caps and press the plug in it. Push the rest of the tube on the other outmost exhaust cap and lead it to the exterior.